

PSE NOTES:


- NEW POLE SHALL SUPPORT PSE'S 1272 100 DEGREE C TRANSMISSION DESIGN STANDARD.
- ANY POLE MOUNTED EQUIPMENT SHALL BE LIMITED TO ONE FACE OR QUADRANT OF THE POLE AND MUST BE INSTALLED SO THAT CLIMBING SPACE PAST THE EQUIPMENT IS MAINTAINED.
- GROUND EQUIPMENT MUST BE LOCATED MINIMUM OF 10 FT. FROM THE BASE OF THE POLE.
- TREE-TRIMMING AND BRUSHING OUT REQUIRED FOR ACCESS.
- FINAL AS-BUILT DRAWINGS AND CLOSE-OUT PHOTOS FROM THIS PROJECT SHALL BE PROVIDED UPON COMPLETION OF THE WORK.



NEW WAVE ARCHITECTURE
 1133 164TH STREET SW
 SUITE 202
 LYNNWOOD, WA 98047
 OFFICE: (425) 778-3800
 JAY@NEWWAVEARCH.COM

DATE: 1-22-19
 PREPARED BY: YML
 APPROVED BY: JYS

SUBMITTALS		
NO.	DATE	DESCRIPTION
1-22-19		FINAL PERMIT
11-4-18		RFDS UPDATE
3-22-18		REVISED PERMIT
11-15-17		REVISED PERMIT
11-1-17		PRELIMINARY PERMIT
10-18-17		REVISED LEASE EXHIBIT
9-20-17		LEASE EXHIBIT



RECEIVED
FEB 29 2019
KING COUNTY
D.P.E.R.

PMSC19-0001

1 **OVERALL SITE PLAN**
 SCALE: 1" = 10' (22x34), 1" = 32' (11x17)

SITE
SEA-IRON HORSE
43307 SE 174TH STREET NORTH BEND, WA 98045
SHEET TITLE
OVERALL SITE PLAN
SHEET NUMBER
A-1

MAIN FILE COPY PMSC19.0001