

## **Fire Prevention Plan**

Potential onsite fire hazards:

- Woodchip stockpiles
- Equipment

Fire Prevention and Emergency Procedures:

- 20ft roads will be constructed around all stockpiles for easy access to all areas of the stockpile.
- No smoking in the material processing, stockpile areas, and on or near equipment.
- Monthly safety meetings will be conducted to go over all safety procedures.
- All equipment will be parked away from stockpiles, will be kept clean of dirt or wood chips, and no fuel will be stored near stockpiles.
- At the end of every shift, a designated safety officer will do a walk around inspection of the site and all stockpiles to ensure there is no smoldering or other potential issues.
- All employees are instructed to alert the fire department in the event of a fire.
- All equipment will be equipped with a fire extinguisher.
- Fire extinguisher, dirt, or water may be used to suffocate small spot fires.
- 225,000 gallon pond will have a fire pump piped to a fire extinguisher to draft water from the pond for fire department access in the case of a fire emergency.